SIPLUS ET 200SP CPU 1512SP F-1P -25...+60°C start up -25°C with conformal coating based on 6ES7512-1SK01-0AB0 . Central processing unit with RAM 300 KB for program and 1 MB for data, 1st interface: PROFINET IRT with 3-port switch, 48 ns bit performance, SIMATIC Memory Card required, Bus Adapter required for Port 1 and

## Data sheet



Figure similar

CPU 1512SP F-1 PN Product type designation HW functional status FS01 Firmware version V1.8 Product function Yes; Only with PROFINET; with minimum OB 6x cycle of 625 µs • Isochronous mode Configuration control Yes via dataset Control alam

Mode selector switch	1	
Supply voltage		
Type of supply voltage	24 V DC	
permissible range, lower limit (DC)	19.2 V	
permissible range, upper limit (DC)	28.8 V	
Reverse polarity protection	Yes	
Mains buffering		

Mains/voltage failure stored energy time	5 ms
Input current	
Current consumption (rated value)	0.6 A
Inrush current, max.	4.7 A; Rated value
l²t	0.14 A <sup>2</sup> ·s
Power	
Infeed power to the backplane bus	8.75 W
Power loss	
Power loss, typ.	5.6 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
• integrated (for program)	300 kbyte
• integrated (for data)	1 Mbyte
Load memory	
Plug-in (SIMATIC Memory Card), max.	32 Gbyte
Backup	
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	48 ns
for word operations, typ.	58 ns
for fixed point arithmetic, typ.	77 ns
for floating point arithmetic, typ.	307 ns
CPU-blocks	
Number of elements (total)	2 000; In addition to blocks such as DBs, FBs and FCs, UDTs, global constants, etc. are also regarded as elements
DB	
Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	1 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	
Number range	0 65 535
• Size, max.	300 kbyte
FC	
Number range	0 65 535
• Size, max.	300 kbyte
OB	
• Size, max.	300 kbyte

<ul> <li>Number of free cycle OBs</li> </ul>	100
<ul> <li>Number of time alarm OBs</li> </ul>	20
<ul> <li>Number of delay alarm OBs</li> </ul>	20
<ul> <li>Number of cyclic interrupt OBs</li> </ul>	20
<ul> <li>Number of process alarm OBs</li> </ul>	50
<ul> <li>Number of DPV1 alarm OBs</li> </ul>	3
<ul> <li>Number of isochronous mode OBs</li> </ul>	1
Number of technology synchronous alarm OBs	2
<ul> <li>Number of startup OBs</li> </ul>	100
<ul> <li>Number of asynchronous error OBs</li> </ul>	4
<ul> <li>Number of synchronous error OBs</li> </ul>	2
<ul> <li>Number of diagnostic alarm OBs</li> </ul>	1
Nesting depth	
• per priority class	24; Up to 8 possible for F-blocks
Counters, timers and their retentivity	
S7 counter	
• Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
• Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
• Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
• Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags),	128 kbyte; Available retentive memory for bit memories, timers,
max.	counters, DBs, and technology data (axes): 88 KB
Flag	16 khida
Number, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	Ven
Retentivity adjustable	Yes
Retentivity preset	No
Local data	

• per priority class, max.	64 kbyte; max. 16 KB per block
Address area	
Number of IO modules	2 048; max. number of modules / submodules
I/O address area	
• Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
per CM/CP	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	
Number of subprocess images, max.	32
Address space per module	
Address space per module, max.	32 byte; For input and output data respectively
Address space per station	
Address space per station, max.	1 280 byte; for central inputs and outputs; depending on configuration
Hardware configuration	
Number of distributed IO systems	2
Number of DP masters	
• Via CM	1
Number of IO Controllers	
• integrated	1
• Via CM	0
Rack	
Modules per rack, max.	64; CPU + 64 modules + server module (mounting width max. 1 m)
<ul> <li>Number of lines, max.</li> </ul>	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots
Time of day	
Clock	
<ul> <li>Type</li> </ul>	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
<ul> <li>Deviation per day, max.</li> </ul>	10 s; Typ.: 2 s
Operating hours counter	

Clock synchronization

Yes supported Yes; Via CM DP module • to DP, master Yes; Via CM DP module • to DP, slave Yes • in AS, master Yes • in AS, slave Yes • on Ethernet via NTP

Number of PROFINET interfaces Number of PROFIBUS interfaces 1; Via CM DP module

#### I. Interface Interface types 3; 1. integr. + 2. via BusAdapter Number of ports Yes • integrated switch Yes: X1 • RJ 45 (Ethernet) Yes; Applicable BusAdapter: BA 2x RJ45, BA 2x FC • BusAdapter (PROFINET) **Protocols** • PROFINET IO Controller Yes Yes PROFINET IO Device Yes • SIMATIC communication Yes • Open IE communication Yes • Web server Yes Media redundancy

Yes

## **PROFINET IO Controller**

# Services

- PG/OP communication Yes - S7 routing - Isochronous mode Yes; Requirement: IRT and isochronous mode (MRPD optional) - Direct data exchange — IRT - MRP Yes; as MRP redundancy manager and/or MRP client; max. number of devices in the ring: 50 - MRPD Yes; Requirement: IRT Yes - PROFlenergy Yes; Max. 32 PROFINET devices - Prioritized startup 128; In total, up to 253 distributed I/O devices can be connected - Number of connectable IO Devices, max. via PROFIBUS or PROFINET 64 - Of which IO devices with IRT, max. - Number of connectable IO Devices for RT, 128 max. 128 - of which in line, max.

— Number of IO Devices that can be	8; in total across all interfaces
simultaneously activated/deactivated, max.	8
Number of IO Devices per tool, max.	
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO
	devices, and on the quantity of configured user data
Update time for IRT	
— for send cycle of 250 μs	250 μs to 4 ms
— for send cycle of 500 μs	500 μs to 8 ms
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
<ul> <li>With IRT and parameterization of "odd"</li> </ul>	Update time = set "odd" send clock (any multiple of 125 µs: 375
send cycles	μs, 625 μs 3 875 μs)
Update time for RT	
— for send cycle of 250 μs	250 μs to 128 ms
— for send cycle of 500 μs	500 μs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— S7 routing	Yes
— Isochronous mode	No
— IRT	Yes
— MRP	Yes
— MRPD	Yes
— PROFlenergy	Yes
— Shared device	Yes
<ul> <li>Number of IO Controllers with shared</li> </ul>	4
device, max.	
2. Interface	
Interface types	
<ul><li>Number of ports</li></ul>	1
• RS 485	Yes; Via CM DP module
Protocols	
<ul> <li>PROFIBUS DP master</li> </ul>	Yes
<ul> <li>PROFIBUS DP slave</li> </ul>	Yes
SIMATIC communication	Yes
Interface types	

RJ 45 (Ethernet)	
• 100 Mbps	Yes
<ul> <li>Autonegotiation</li> </ul>	Yes
<ul> <li>Autocrossing</li> </ul>	Yes
<ul> <li>Industrial Ethernet status LED</li> </ul>	Yes
RS 485	
Transmission rate, max.	12 Mbit/s
Protocols	
Number of connections	
<ul><li>Number of connections, max.</li></ul>	88
<ul> <li>Number of connections reserved for ES/HMI/web</li> </ul>	10
<ul> <li>Number of connections via integrated interfaces</li> </ul>	88
<ul> <li>Number of S7 routing paths</li> </ul>	16
Redundancy mode	
Media redundancy	
— MRP	Yes; as MRP redundancy manager and/or MRP client; max. number of devices in the ring: 50
<ul> <li>Switchover time on line break, typ.</li> </ul>	200 ms
<ul> <li>Number of stations in the ring, max.</li> </ul>	50
SIMATIC communication	
S7 communication, as server	Yes
S7 communication, as client	Yes
• User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
	V

Open IE communication		
• TCP/IP	Yes	
— Data length, max.	64 kbyte	
<ul> <li>several passive connections per port, supported</li> </ul>	Yes	
• ISO-on-TCP (RFC1006)	Yes	
— Data length, max.	64 kbyte	
• UDP	Yes	
— Data length, max.	1 472 byte	
• DHCP	No	

• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Web server	

HTTPYes; Standard and user-defined pagesHTTPSYes; Standard and user-defined pages

PROFIBUS DP master

<ul> <li>Number of connections, max.</li> </ul>	48
Services	
— PG/OP communication	Yes
— S7 routing	Yes
<ul> <li>Data record routing</li> </ul>	Yes
— Isochronous mode	No
— Equidistance	No
— Number of DP slaves	125
<ul> <li>Activation/deactivation of DP slaves</li> </ul>	Yes
Further protocols	
• MODBUS	Yes; MODBUS TCP
S7 message functions	
Number of login stations for message functions, max.	32
Program alarms	Yes
Number of configurable program messages, max.	5 000
Number of simultaneously active program alarms	
<ul> <li>Number of program alarms</li> </ul>	300
<ul> <li>Number of alarms for system diagnostics</li> </ul>	100
<ul> <li>Number of alarms for motion technology objects</li> </ul>	80
Test commissioning functions	
Test commissioning functions Joint commission (Team Engineering)	Yes; Parallel online access possible for up to 3 engineering
Joint commission (Team Engineering)	Yes; Parallel online access possible for up to 3 engineering systems
Joint commission (Team Engineering)  Status block	
Joint commission (Team Engineering)  Status block Single step	systems
Joint commission (Team Engineering)  Status block	systems Yes; Up to 8 simultaneously (in total across all ES clients) No
Joint commission (Team Engineering)  Status block Single step	systems  Yes; Up to 8 simultaneously (in total across all ES clients)  No  Yes
Joint commission (Team Engineering)  Status block Single step Status/control	systems Yes; Up to 8 simultaneously (in total across all ES clients) No
Joint commission (Team Engineering)  Status block  Single step  Status/control  • Status/control variable	systems  Yes; Up to 8 simultaneously (in total across all ES clients)  No  Yes
Joint commission (Team Engineering)  Status block Single step Status/control  • Status/control variable  • Variables	systems  Yes; Up to 8 simultaneously (in total across all ES clients)  No  Yes
Joint commission (Team Engineering)  Status block Single step Status/control  • Status/control variable  • Variables  • Number of variables, max.	systems  Yes; Up to 8 simultaneously (in total across all ES clients)  No  Yes  Inputs, outputs, memory bits, DB, times, counters
Joint commission (Team Engineering)  Status block  Single step  Status/control  • Status/control variable  • Variables  • Number of variables, max.  — of which status variables, max.	yes; Up to 8 simultaneously (in total across all ES clients) No  Yes Inputs, outputs, memory bits, DB, times, counters  200; per job
Joint commission (Team Engineering)  Status block Single step Status/control  • Status/control variable  • Variables  • Number of variables, max.  — of which status variables, max.  — of which control variables, max.	yes; Up to 8 simultaneously (in total across all ES clients) No  Yes Inputs, outputs, memory bits, DB, times, counters  200; per job
Joint commission (Team Engineering)  Status block Single step Status/control  Status/control variable  Variables  Number of variables, max.  of which status variables, max.  of which control variables, max.  Forcing	yes; Up to 8 simultaneously (in total across all ES clients) No  Yes Inputs, outputs, memory bits, DB, times, counters  200; per job 200; per job
Joint commission (Team Engineering)  Status block Single step Status/control  Status/control variable  Variables  Number of variables, max.  of which status variables, max.  of which control variables, max.  Forcing  Forcing	yes; Up to 8 simultaneously (in total across all ES clients) No  Yes Inputs, outputs, memory bits, DB, times, counters  200; per job 200; per job
Joint commission (Team Engineering)  Status block Single step Status/control  Status/control variable  Variables  Number of variables, max.  of which status variables, max.  of which control variables, max.  Forcing  Forcing  Forcing  Forcing, variables	systems Yes; Up to 8 simultaneously (in total across all ES clients) No  Yes Inputs, outputs, memory bits, DB, times, counters  200; per job 200; per job Yes Inputs, outputs
Joint commission (Team Engineering)  Status block Single step Status/control  Status/control variable  Variables  Number of variables, max.  of which status variables, max.  of which control variables, max.  Forcing  Forcing  Forcing  Forcing, variables  Number of variables, max.	systems Yes; Up to 8 simultaneously (in total across all ES clients) No  Yes Inputs, outputs, memory bits, DB, times, counters  200; per job 200; per job Yes Inputs, outputs
Joint commission (Team Engineering)  Status block Single step Status/control  Status/control variable  Variables  Number of variables, max.  of which status variables, max.  of which control variables, max.  Forcing  Forcing  Forcing  Forcing, variables  Number of variables, max.  Diagnostic buffer	yes; Up to 8 simultaneously (in total across all ES clients) No  Yes Inputs, outputs, memory bits, DB, times, counters  200; per job 200; per job  Yes Inputs, outputs 200
Joint commission (Team Engineering)  Status block Single step Status/control  Status/control variable  Variables  Number of variables, max.  of which status variables, max.  of which control variables, max.  Forcing  Forcing  Forcing  Forcing  Prorcing, variables  Number of variables, max.  Diagnostic buffer  present	yes; Up to 8 simultaneously (in total across all ES clients)  No  Yes Inputs, outputs, memory bits, DB, times, counters  200; per job  200; per job  Yes Inputs, outputs 200  Yes
Joint commission (Team Engineering)  Status block Single step Status/control  Status/control variable  Variables  Number of variables, max.  of which status variables, max.  of which control variables, max.  Forcing  Forcing  Forcing  Forcing, variables  Number of variables, max.  Diagnostic buffer  present  Number of entries, max.	yes; Up to 8 simultaneously (in total across all ES clients)  No  Yes Inputs, outputs, memory bits, DB, times, counters  200; per job  Yes Inputs, outputs 200  Yes Inputs, outputs 200  Yes 1 000

### Interrupts/diagnostics/status information Diagnostics indication LED • RUN/STOP LED Yes Yes • ERROR LED Yes MAINT LED Yes Monitoring of the supply voltage (PWR-LED) Yes Connection display LINK TX/RX Supported technology objects Motion Control Yes Speed-controlled axis - Number of speed-controlled axes, max. 6; Max. number of speed-controlled axes (requirement: there must be no other motion technology objects created) Positioning axis 6; Max. number of positioning axes (requirement: there must be - Number of positioning axes, max. no other motion technology objects created) • Synchronized axes (relative gear synchronization) 3; Max. number of synchronous axes (requirement: there must be - Number of axes, max. no other motion technology objects created) • External encoders 6; Max. number of external encoders (requirement: there must be - Number of external encoders, max. no other motion technology objects created) Controller Yes; Universal PID controller with integrated optimization • PID\_Compact • PID\_3Step Yes; PID controller with integrated optimization for valves • PID-Temp Yes; PID controller with integrated optimization for temperature Counting and measuring Yes • High-speed counter Ambient conditions Ambient temperature during operation -25 °C; = Tmin • horizontal installation, min. • horizontal installation, max. 60 °C; = Tmax -25 °C; = Tmin • vertical installation, min. 50 °C; = Tmax • vertical installation, max. Altitude during operation relating to sea level 5 000 m • Installation altitude above sea level, max. Restrictions for installation altitudes > 2 000 m, see entry ID: • Ambient air temperature-barometric pressure-109763260 altitude Relative humidity 100 %; RH incl. condensation / frost (no commissioning in • With condensation, tested in accordance with bedewed state), horizontal installation IEC 60068-2-38, max.

Resistance

Coolants and lubricants	
Resistant to commercially available coolants and lubricants	Yes; Incl. diesel and oil droplets in the air
Use in stationary industrial systems	
<ul> <li>to biologically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request
<ul> <li>to chemically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); $^{\star}$
<ul> <li>to mechanically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3S4 incl. sand, dust, *
<ul> <li>Against mechanical environmental conditions acc. to EN 60721-3-3</li> </ul>	Yes; Class 3M8 using the SIPLUS Mounting Kit ET 200SP (6AG1193-6AA00-0AA0)
Use on ships/at sea	
<ul> <li>to biologically active substances according to EN 60721-3-6</li> </ul>	Yes; Class 6B2 mold and fungal spores (excluding fauna); Class 6B3 on request
<ul> <li>to chemically active substances according to EN 60721-3-6</li> </ul>	Yes; Class 6C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); $^{\star}$
<ul> <li>to mechanically active substances according to EN 60721-3-6</li> </ul>	Yes; Class 6S3 incl. sand, dust; *
<ul> <li>Against mechanical environmental conditions acc. to EN 60721-3-6</li> </ul>	Yes; Class 6M4 using the SIPLUS Mounting Kit ET 200SP (6AG1193-6AA00-0AA0)
Usage in industrial process technology	
<ul> <li>Against chemically active substances acc.</li> <li>to EN 60654-4</li> </ul>	Yes; Class 3 (excluding trichlorethylene)
<ul> <li>Environmental conditions for process, measuring and control systems acc. to ANSI/ISA-71.04</li> </ul>	Yes; Level GX group A/B (excluding trichlorethylene; harmful gas concentrations up to the limits of EN 60721-3-3 class 3C4 permissible); level LC3 (salt spray) and level LB3 (oil)
Remark	
<ul> <li>Note regarding classification of environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04</li> </ul>	* The supplied plug covers must remain in place over the unused interfaces during operation!
Conformal coating	
<ul> <li>Coatings for printed circuit board assemblies acc. to EN 61086</li> </ul>	Yes; Class 2 for high reliability
<ul> <li>Protection against fouling acc. to EN 60664-3</li> </ul>	Yes; Type 1 protection
<ul> <li>Military testing according to MIL-I-46058C, Amendment 7</li> </ul>	Yes; Discoloration of coating possible during service life
<ul> <li>Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC-CC-830A</li> </ul>	Yes; Conformal coating, Class A
Configuration	
Programming	
Programming language	
— LAD	Yes; incl. failsafe

— FBD	Yes; incl. failsafe
— STL	Yes
— SCL	Yes
— GRAPH	Yes
	165
Know-how protection	
<ul> <li>User program protection/password protection</li> </ul>	Yes
<ul> <li>Copy protection</li> </ul>	Yes
<ul> <li>Block protection</li> </ul>	Yes
Access protection	
Protection level: Write protection	Yes
<ul> <li>Protection level: Read/write protection</li> </ul>	Yes
<ul> <li>Protection level: Complete protection</li> </ul>	Yes
Cycle time monitoring	
• lower limit	adjustable minimum cycle time
• upper limit	adjustable maximum cycle time
Dimensions	
Width	100 mm
Height	117 mm
Depth	75 mm
Weights	
Weight, approx.	310 g
last modified:	05/26/2020